

DC0836.4

Created on 02/02/2010 09:50:00



DECLARATION OF CONFORMITY

We **Novar ED&S Ltd (MK Electric)**
of **The Arnold Centre, Paycocke Road, Basildon, Essex. UK. SS14 3EA**

Declare under our sole responsibility that the following products:

Albany Plus and Chroma Plus socket-outlets, 250V a.c., 13A

List No's.	Description
K2958 MCO/SAB/BSS/PCR/BLU	1 gang, DP, switched, dual earth. BLU marked "Medical Equipment Only"
K2958D6 MCO/SAB/BSS	1 gang, DP, switched, dual earth, red rocker
K2458 MCO/SAB/BSS/PCR	1 gang, DP, switched, dual earth, with neon
K2948 MCO/SAB/BSS/PCR	2 gang, DP, switched
K2948D6 MCO/SAB/BSS	2 gang, DP, switched, red rockers
K2448 MCO/SAB/BSS/PCR	2 gang, DP, switched, with neons
K2448D6 MCO/SAB/BSS/PCR	2 gang, DP, switched, red rockers, with neons
K2947 MCO/SAB/BSS	2 gang, DP, switched, outboard rockers, dual earth
K2947D6 MCO/SAB/BSS	2 gang, DP, switched, outboard red rockers, dual earth
K2947CE MCO/SAB/BSS	2 gang, DP, switched, outboard rockers, clean earth
K2949 MCO/SAB/BSS	1 gang, DP, switched, lockable
K732 MCO/SAB/BSS/PCR/BLU	1 gang unswitched. BLU marked "Medical Equipment Only"
K733 MCO/SAB/BSS/PCR	2 gang unswitched

To which this declaration relates, are in conformity with the test requirements of the following standards:

BS 1363-2:1995

Specification for 13A plugs, socket-outlets, adaptors and connection units. Part 2. Specification for 13A switched and unswitched socket-outlets

Support Documentation reference:

04013677/01, 04013677/07, 04013677/08, 04013677/09, 0406010B, 0407016B, 0408009B, 0409005B, N26725, 38386, 0709008B

K. Davis.

Signature: _____

Technical Manager

(GB)



MK Electric

Novar ED&S Limited

Registered Office: Honeywell House, Arlington Business Park, Bracknell, Berkshire RG12 1EB