## ELSEWEDY C A B L E S

## **DECLARATION OF PERFORMANCE**

## No. : UCCD-01-17

1. Product type: BS 6724 (circular Conductor)			
2. Conduc	ctor size & Range: Cores (2, 3	, 4, 5)	1.5 mm <sup>2</sup> :16 mm <sup>2</sup>
	Cores (7, 12,	and 19)	1.5 mm <sup>2</sup> :4 mm <sup>2</sup>
3. Intended use:			
Supply of electricity in buildings and other civil engineering			
Works with the objective of limiting the generation and spread of fire and smoke			
4. Manufacturer:			
	UIC (United Industries Cables)		
	10th of Ramadan City, Zone A3, Egypt		
1.077 State of 194	=EL SEWEDY CABLES=		
5. System/s of AVCP: System 3			
6. Notified product certification body <u>BASEC</u> No. 2661			
7. Declared Performance			
	Essential characteristics	Performance	Harmonized technical specification
	Reaction to fire	Dca	EN 50575:2014+A1:2016

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

None

Signed for and on behalf of the manufacturer by:

**Dangerous substances** 

216/2022 Eng. Haitham M. Aly **Quality Assurance Manager** 

Date: 22 June 2017

Office: plot 27, 1<sup>st</sup> district.5<sup>th</sup> settlement, new Cairo. Tel: 72599732-27599733-27599734 Fax: 27599735 P.O.Box:311-post code: 11853

Factory: 10th of Ramadan City Zone, A 3, Tel.: (20554) 411350 fax: (20554)411366 PO.Box: 1748 post code: 10505