# ELSEWEDY CABLES

# **DECLARATION OF PERFORMANCE**

No.: UCCE-01-17

1. Product type: (Small Circular Conductors) BS 5467

2. Conductor size & Range: Cores (2, 3, 4, 5, 7, 12, 19, 27, 37) 1.5 mm<sup>2</sup>: 4 mm<sup>2</sup>

Cores (2, 3, 4, and 5)

6 mm<sup>2</sup>:16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables) 10th of Ramadan City, Zone A3, Egypt =EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

- 6. Notified product certification body BASEC No. 2661
- 7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	<u>,</u>

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Eng. Haitham M. Aly

213/242 Quality Assurance Manager

Date: 13 March 2017

# ELSEWEDY

## **DECLARATION OF PERFORMANCE**

No.: UCCE-02-17

Product type: (Small circular conductors) BS 6724

2. Conductor size & Range: Cores (2, 3, 4, 5, 7, 12, 19, 27, 37) 1.5 mm<sup>2</sup>: 4 mm<sup>2</sup>

Cores (2, 3, 4, and 5)

6 mm<sup>2</sup>:16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables) 10th of Ramadan City, Zone A3, Egypt =EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

- 6. Notified product certification body **BASEC** No. 2661
- 7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	3

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Quality Assurance Manager 317 Med

Date: 13 March 2017



No.: UCCE-03-17

Product type: H07V-U/R

Conductor size & Range: Cores (1) H07V-U 1.5 mm<sup>2</sup>: 10 mm<sup>2</sup>

Cores (1) H07V-R 1.5 mm<sup>2</sup>: 16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables) 10th of Ramadan City, Zone A3, Egypt =EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

- 6. Notified product certification body BASEC No. 2661
- 7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	3

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

13131212 Signed for and on behalf of the manufacturer by:

Eng. Haitham M. Aly

Quality Assurance Manager

Date: 13 March 2017

## ELSEWEDY CABLES

# **DECLARATION OF PERFORMANCE**

No.: UCCE-04-17

Product type: H07V-K

Conductor size & Range: cores (1) 1.5 mm<sup>2</sup>: 16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables) 10th of Ramadan City, Zone A3, Egypt =EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

- 6. Notified product certification body BASEC No. 2661
- 7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Eng. Haitham M. Aly

Quality Assurance Manager 11

Date: 13 March 2017



No.: UCCE-05-17

Product type: H07Z-U/R

Conductor size & Range: H07Z-U cores (1) 1.5 mm<sup>2</sup>

H07Z-R cores (1) 1.5 mm<sup>2</sup>: 16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables) 10th of Ramadan City, Zone A3, Egypt =EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

- 6. Notified product certification body BASEC No. 2661
- 7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	3

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Quality Assurance Manager

Date: 13 March 2017

# ELSEWEDY C A B L E S

## **DECLARATION OF PERFORMANCE**

No.: UCCE-06-17

1. Product type: H07Z-K

2. Conductor size & Range: cores(1) 1.5 mm<sup>2</sup>: 16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables)

10th of Ramadan City, Zone A3, Egypt

=EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

1713174

6. Notified product certification body **BASEC** No. 2661

7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Eng. Haitham M. Aly

Quality Assurance Manager-

Date: 13 March 2017



No.: UCCE-07-17

1. Product type: NYY Circular Conductor

2. Conductor size & Range: Cores(1) 10 mm<sup>2</sup>

Cores (3, 4, and 5) 1.5 mm<sup>2</sup>:16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables)

10th of Ramadan City, Zone A3, Egypt

=EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

- 6. Notified product certification body BASEC No. 2661 performed the determination of product type and of FPC
- 7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	<u> </u>

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Eng. Haitham M. Aly

Quality Assurance Manager

Date: 13 March 2017



No.: UCCE-08-17

1. Product type: R2V XP C 32-321 Circular Conductor

2. Conductor size & Range: Cores (1,2,3,4,5,7,12,19,24,27,37) 1.5 mm<sup>2</sup>: 2.5 mm<sup>2</sup>

Cores (1, 2, 3, 4, and 5)

4 mm<sup>2</sup>: 16 mm<sup>2</sup>

3. Intended use:

Supply of electricity in buildings and other civil engineering

Works with the objective of limiting the generation and spread of fire and smoke

4. Manufacturer:

UIC (United Industries Cables)

10th of Ramadan City, Zone A3, Egypt

=EL SEWEDY CABLES=

5. System/s of AVCP:

System 3

- 6. Notified product certification body BASEC No. 2661 performed the determination of product type and of FPC
- 7. Declared Performance

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014+A1:2016
Dangerous substances	None	١

8. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Eng. Haitham M. Aly

Quality Assurance Manager

Date: 13 March 2017